

Advanced Energy Conference New York 2018

Making Commercial Buildings Responsive Loads

Terry Casey
Intellastar

Making Buildings Response Loads

- Why should Buildings be Responsive Loads
- What techniques have we used
- How do the results stack up


Why should Buildings be Responsive Loads




Electricity
Supply
is changing




Demand Profile is Changing too



The Duck Curve



Projected effect of EV's – the Dragon Curve



Different Methods to pay for Demand Reduction

Demand Response

paid to reduce demand

- **Capacity Market**
Infrequent, long notice 24 hours
- **Spinning Reserves**
30 min to 2 hours notice
but 6 sec reporting required
- **Frequency Regulation**
30 sec to 2 min response

Time of Use Pricing

Price changes with availability

- **DATOD**
Day Ahead Time of Day Pricing
Hourly pricing set previous day
- **Spot Pricing**
Dynamic Market price
Various forms

Peak Demand Pricing

Based on max demand in a period

Example

Load Management
at a Retail Facility in Buffalo NY
with multiple Roof Top AC Units

Techniques Deployed


Energy Efficiency

- Time Schedules
- Demand Based Ventilation
- Analytics for Sensor and Plant Failure


Demand Limiting

- Load Synchronization
- Load Shifting by Temperature change


With individual Controls, demand is quite variable




With Synchronized Control, Load is more even and Peak Demand lower




Load Synchronisation




It works in reality




Load Shifting by changing Temperature Setpoint



Reducing Peak Demand by Ramping Setpoint back



Adding in pre-Cooling of the space




Results


1-Jun-2016 15 min 21.5 \$

Jun-2016 0.12 \$

Power • Peak Demand vs Baseline



Consumption • Daily Gradient




Summary Data
from 2016-06-01 to 2016-06-30


Peak Demand
kW Reduction: 35.77kW
Cost Saved: \$769.03
Percent Diff: 17.61%

Energy Usage
kWh Reduction: 10189.61kWh
Cost Saved: \$1222.75
Percent Diff: 38.74%

Peak Demand vs Baseline • Monthly



Consumption Comparison • Energy vs Baseline



Summary Data
for 2016

Year Peak kW Reduction: 37.1kW
Year Total Usage Reduction: 129640kWh

Results

Energy Consumption KWHr reduction 38%

- A number of time schedule and Plant faults discovered

Peak Demand Reduced by 17%

- Only Load Synchronization applied
- Time of Use ToU pricing not offered for this site

Simple Payback

- Less than 12 months